

Evaluation of the applicability of pre-evaporative cooling of air in front of the cooling tower in the conditions of the third climatic zone of the Russian Federation

Balzamov D., Sabitov L., Timershin B., Yu Balzamova E.
Kazan Federal University, 420008, Kremlevskaya 18, Kazan, Russia

Abstract

© Published under licence by IOP Publishing Ltd. This article provides an evaluation of the applicability of the evaporative cooling system of air supplied to the cooling tower in order to reduce the temperature of the cooled water at the outlet from the cooling tower in the conditions of the third climatic zone of the Russian Federation.

<http://dx.doi.org/10.1088/1757-899X/412/1/012006>

References

- [1] Ruzankov V N, Laditskaya N V, Kruglov G A and Danilin V M 1974 Typical normative characteristic of the turbine unit PT-60-130/13 (LMZ) approved Ch. Ing. Glavtekhupravleniya on the operation of power systems V. Zubenko
- [2] Laptev A G and Vigayeva I A 2004 Design and calculation of industrial cooling towers: Monograph (Kazan: KSPEU) 180
- [3] Determination of the economic effect of the cooling tower Number 2 of Astrakhanskaya CHPP-2 from the introduction of the evaporative cooling of outdoor air 2007 S. Petersburg: JSC "All-Russian Scientific Research Institute of Hydraulic Engineering" B.E. Vedeneeva" p 25 - ref-separator -